

H19-311^{Q&As}

Huawei Certified Pre-sales Specialist-UPS-CHS

Pass Huawei H19-311 Exam with 100% Guarantee

Free Download Real Questions & Answers **PDF** and **VCE** file from:

<https://www.leads4pass.com/h19-311.html>

100% Passing Guarantee
100% Money Back Assurance

Following Questions and Answers are all new published by Huawei
Official Exam Center

-  **Instant Download** After Purchase
-  **100% Money Back** Guarantee
-  **365 Days** Free Update
-  **800,000+** Satisfied Customers



QUESTION 1

For two UPS5000-E (50 kA power module) 150 kVA with 2+0 rack redundancy, a () general input switch is required for the general input power distribution cabinet.

- A. 250 A
- B. 320 A
- C. 500 A
- D. 630 A

Correct Answer: D

QUESTION 2

Which of the following voltage systems does the UPS5000-E support? (Multiple Choice)

- A. 380 V
- B. 415 V
- C. 480V
- D. 400 V

Correct Answer: ABD

QUESTION 3

Which of the following components is included in the UPS5000-E (25-75 kVA)? (Multiple Choice)

- A. Input switch
- B. Output switch
- C. Battery switch
- D. Maintenance bypass switch

Correct Answer: ACD

QUESTION 4

The UPS5000-E (25-125 kVA) power module height is (), and the system efficiency is ().

- A. 3U, 95.5%

B. 3U, 96%

C. 2U, 95.5%

D. 2U, 96%

Correct Answer: D

QUESTION 5

The UPS5000-E (25-75 kVA) supports a maximum of () battery modules.

A. 16

B. 128

C. 144

D. 150

Correct Answer: C

[H19-311 Practice Test](#)

[H19-311 Study Guide](#)

[H19-311 Braindumps](#)